




# Thermal **D**esorption: A Solution for Insoluble Case

**Session C** : innovations techniques

- Based upon **venting** principles
  - Only available for pollutants with a high vapor saturation pressure:  $P_{\text{sat}} > 100\text{-}150 \text{ Pa}$  (1 mm Hg)
  - Now,  $P_{\text{sat}}$  is greatly influenced by temperature  $\rightarrow$  given by Antoine's Equation


Curves of saturation pressure : for each compound, the vapor partial pressure grows with temperature  
 100 kPa = BP under 1 atm pressure



## Technical Principle

- $P_{\text{sat}}$  for naphthalene at 20°C is about 7,2 Pa (too low to be drawn). We reached an average temperature of 87°C →  $P_{\text{sat}}$  raises to 1,37 kPa
- It is 190 times more; it means remediation should go 190 times faster


➤ To allow a weakly volatile pollutant to be treated by venting!






## VALGO's Approach

- A Strategy based upon modelling and pilots:



- Preliminary assays In VALGO's lab:

Contaminated soils are held in a desorption unit (oven), with a ventilation, at several temperatures. Heated soils are periodically sampled during desorption and remaining amount of pollutants is measured, to draw kinetics.




## Validation of chemical interactions

- Air permeability assay



- Plot depressure data in soil and all other parameters used to adjust MFRKINV model:




**Determine radial and vertical parameters of soil's permeability to air**



## ON SITE TESTS

- Air permeability test



choose a pore flow speed over 0,01 cm/s




**Determine the ROI (radius of influence) of the extraction needles**





# MODELLING









# MODELLING PHASE

- Partnership with IMFT
- The multi-physical model (OpenFoam) for the flow in porous medium is taking account of air gases, water and a pollutant.
- Soil's matrix is defined by several dimensions, including permissivity
- Calculation starts when applying a temperature and a pressure differences between 2 points
- The program calculates flow and pressure vectors and their place-to-place evolution during time






## PILOT PHASE





## PILOT PHASE





## PILOT PHASE



→ validation of choice



## FULL SCALE – VALGO’S OFFER

- Optimize each step of the process
  - **Heating**
  - **Gases collection**
  - **Cooling**
  - **Implementation & treatment**





# HEATING

- Calculate the total amount of energy to provide


PRE DIMENSIONNEMENT TRAITEMENT EN PILE RECHAUFFEURS ELECTRIQUES		
Renseigner les cellules en jaune Résultats dans les cellules en vert		
<b>Données d'entrée</b>		
Paramétrage humidité	25	°C
T° ambiante	20	°C
Poids spécifique liège	1000	kg/m³
Valeur liège (a3)	1000	m³
Delta T° liège entre T° ambiante et adiabatique (C)	30	°C
Temps de séchage total (H)	2200	h
Paliers à la longueur de séchage	20	h
Paliers entre les lièges	0	mm
<b>Résultats de dimensionnement</b>		
Nombre de chauffeuses nécessaires	999	n
Puissance électrique chauffeuses	637	kW
<b>PRESENTATION RESULTATS POUR MEMOIRE TECHNIQUE</b>		
Paramètres	Valeur	Unité
Chaleur spécifique liège	2	KJ/Kg°C
Paramétrage humidité	25	°C
T° ambiante	20	°C
Valeur de liège	1000	kg/m³
Poids spécifique liège	1000	kg/m³
Poids de liège	2 200 000	kg
Poids d'eau	2 200 000	kg
Chaleur spécifique eau	2 057	KJ/Kg
Rendement de la chauffe	95	%
Énergie totale	10	h
Perte d'air chaud	5	h
Temps de séchage	1000	h
Chaleur nécessaire à la sécher à T°	2 200 000	kJ
Chaleur nécessaire à la sécher à la température de l'eau	2 200 000	kJ
Chaleur totale	2 200 000	kJ
Temps de chauffe	2 200	h
Puissance nécessaire	999	kW
Puissance à installer	637	kW
<b>Géométrie pile</b>		
Longueur L	24,00	m
Longueur de la face des lièges (L)	37,00	m
Perte des lièges de la pile (mm/TV par m²)	1,0	mm
H	1,0	m
V	1,0	m
Nombre pile	1,00	n
Épaisseur de liège de séchage	8,00	mm
Épaisseur des lièges	1,00	mm

Zone de calcul	
<b>Données rendement et efficacité</b>	
Chaleur spécifique liège	2057 KJ/Kg
Chaleur spécifique liège	2 KJ/Kg°C
Chaleur spécifique eau	4,18 KJ/Kg°C
Rendement de la chauffe	95%
Perte d'air chaud	5%
Énergie totale	10%
<b>Calcul énergétique</b>	
puissance totale	2 200 000 kW
puissance liège	2 200 000 kW
Chaleur nécessaire à la chauffe liège	2 200 000 kW
puissance eau	2 200 000 kW
Chaleur nécessaire à la chauffe eau	2 200 000 kW
Chaleur nécessaire à la sécher liège	2 200 000 kW
Chaleur totale	2 200 000 kW
Puissance totale	2 200 000 kW
Puissance à installer	637 kW



## COLLECTING GASES

- Similar to “classical” venting but with heat resistant materials (steel, stainless steel, suited piping...)
- + cooling exchangers







# IMPLEMENTATION

- Building pile or in-situ?
  - pile: classical leveling engines
  - in-situ → needs drilling works
- Insulating → hunting losses, spare money
  - Depending of implementation, several solutions are available: rockwool panels, cellular concrete, clean earth






## CASE STUDY

- Aluminium industry – Southwestern France
  - Electrical station → PCB spillage on the floor
  - Reported amounts between 20 and 200ppm.
  - About 3000m<sup>3</sup> of polluted soils to be treated




Optimizing parameters

→ Led to pile building






## CASE STUDY: heating








## CASE STUDY: whole plant






# EXTRACTION & TREATMENT OF VAPORS





# TREATING CONDENSATES







## STORAGE FOR CONDENSATES





## VERY INDUSTRIAL IMPLEMENTATION

- 47 heating tubes and burners.
- 94 Venting tubes
- 4 electrical panels
- 4 propane tanks
- 2 condensation skids
- 2 water and air treatment units
- monitoring unit + data acquirement



## VERY INDUSTRIAL IMPLEMENTATION





## **SURVEY PROTOCOL**



- Temperature
  - T° <200°C : light survey
  - T° >200°C : heavy survey
- Full survey of emissions: PCBs, HCl, (H)VOCs, Dioxins & Furanes
- combustion Exhausts : unburned compounds, CO, SO<sub>2</sub>, Nox
- Automated security management with GSM reports






# TEMPERATURE SURVEY

## Temperatures of cold points



- Results





## ANALYTICAL RESULTS

Final analysis

Maille	L2-1	L2-2	L2-3	L2-4	L1-1	L1-2	L1-3	L1-4
[PCB] mg/Kg	3,10	8,78	2,31	2,76	1,79	0,84	2,25	5,10


For a 10 mg/kg threshold

+ no impact in environment





# MERCI DE VOTRE ATTENTION



VALGO – Laboratoire  
72, bd A. Briand  
76650 PETIT COURONNE

Contact :

[laurent.thannberger@valgo.com](mailto:laurent.thannberger@valgo.com)

VALGO – Sud-Ouest  
2, av Gutenberg  
31120 PORTET sur Garonne

Contact :

[amine.haouara@valgo.com](mailto:amine.haouara@valgo.com)